

CERTIFICATE OF COMPLIANCE

Certificate Number 20140620-R21925
Report Reference R21925-20080313
Issue Date 2014-JUNE-20

Issued to: BETEC CAD INDUSTRIES (FZC)
PLOT P4-02
SAIF ZONE
PO BOX 8805
SHARJAH UNITED ARAB EMIRATES

**This is to certify that
representative samples of**

DAMPERS FOR FIRE BARRIER AND SMOKE
APPLICATIONS

See addendum page

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.


Standard(s) for Safety:

Fire Dampers, UL 555

Additional Information:

See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Classification Mark should be considered as being covered by
UL's Classification and Follow-Up Service.

The UL Classification Mark includes: UL in a circle: with the word "CLASSIFIED"  (as shown); a control
number (may be alphanumeric) assigned by UL; a statement to indicate the extent of UL's evaluation of
the product; and the product category name (product identity) as indicated in the appropriate UL
Directory.

Look for the UL Classification Mark on the product.



William R. Carney, Director, North American Certification Programs

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20140620-R21925
Report Reference R21925-20080313
Issue Date 2014-JUNE-20

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Fire Dampers For Use In Static Systems,

1½ Hr Fire endurance rating, Model MFD-GB/SB/GSB/SGB-20-A/R & Model MFD-GB/SB/GSB/SGB-F-20-A/R.

3 Hr Fire endurance rating, Model MFD-GB/SB/GSB/SGB-30-A/R, Model MFD-GB/SB/GSB/SGB-F-30-A/R & Model MFD-GB-31-A/R.

Fire dampers for use in dynamic systems,

1½ Hr Fire endurance rating, Model MFD-GB/SB/GSB/SGB-D-20-A/R

3 Hr Fire endurance rating, Model MFD-GB/SB/GSB/SGB-D-30-A/R

GB: GI Frame / GI Blade
SB: SS Frame / SS Blade
GSB: GI Frame / SS Blade
SGB: SS Frame / GI Blade
R: Round Spigot



William R. Carney, Director, North American Certification Programs

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

