

## UL 555/555S - Classified Motorized Fire Smoke Damper

## B-30 Series

**Type** : Motorized Fire Smoke Damper With Melting Fuse

**Model** : MSFD-GB-F-30C2-A/R

**Fire Rating** : 30 Series-3 hour.

**Leakage Rating** : Class-II

**Blade Type** : 3V Single Skin; **A** : Parallel Operation

**Construction** : Galvanized Steel (GI)

MSFD GB-F- 30 Series is a high performance UL 555 / 555S Classified combination of fire and smoke damper with 3hr. fire rating , installed vertically or horizontally (with blades running horizontally) and is rated for airflow and leakage Class-II leakage in either direction.

### UL-555 Test Ratings

Fire Rating : 3 hrs  
 Leakage Rating : Class - II  
 Max Velocity : 2000 fpm  
 Temperature : 250 °F (121 °C)  
 Max Operating Pressure: 4 in. w.g (1000 pa)

### Standard Construction

#### Frame

16 gauge (1.4 mm - 1.7 mm) thick galvanized steel.

#### Blades

Parallel operated 3 'V' type blade made of 16 gauge (1.4 mm - 1.7 mm) thick galvanized steel.

#### Blade Seals

Silicon rubber blade seals.

#### Jamb Seals

Stainless steel.

#### Jack Shaft

12 mm diameter Galvanized steel shaft.

#### Spring

Mild steel Spring ( 30lb).

#### Thermal Response Device (TRD)

165°F.

#### Fusible Link

165°F.

#### Actuator

Honeywell (24V AC, 120V AC, 230V AC).

#### Sleeve

Minimum 0.9 mm, single section is field or factory installed.

Multiple section is factory installed.

Sleeve thickness as per NFPA table 3-4.6.3.

#### Limit Switches

For BMS open / close indication.

### Optional Fittings

#### Retaining Angles

1½" x 1½" x 16 gauge (40 x 40 x 1.5 mm).

#### Indicator

Externally mounted open, close visible Indicator.

#### Push Button

For manual reset of damper.

#### Transitions (R)

Neck adapter for round duct connections.

#### Junction Box



MSFD-GB-F-30C2-A/R

Model : MSFD-GB-F-30C2-A/RUL 555/555S Damper meets the required standards of SMACNA, NFPA, IBC, BOCA, ICBO, UL.

Actuator Location		Operating Voltage	
Standard	Optional	Standard	Optional
Left Side	Right side	230 V	120 V / 24 V

**Actuator location standard:** Left side from rear view (Jack shaft view)

Note :

FC : Fail Close in the event of Fire

FO : Fail Open in the event of Fire

**WHILE ORDERING INDICATE THE DAMPER IS FC/FO (FAIL CLOSE / FAIL OPEN)**

**Note** : \* Standard Fusible link temperature is 165°F. Above 165°F available upon customer request.

Minimum Sleeve thickness for Breakeaway joints as per NFPA 90A Table 3-4.6.3			
Air Duct Diameter or Maximum Width		Minimum sleeve thickness	
Inch	mm	Inch	gauge
12 or Less	305	0.018	26
13-30	330-762	0.024	24
31-54	787-1372	0.03	22
55-84	1397-2134	0.036	20
85 or more	2159	0.047	18

### Optional Construction (UL Certification N/A)

**Frame** : Stainless Steel 16 gauge (304/316L)

**Blade** : Stainless Steel 16 gauge (304/316L)

Selected Products of the company have been Classified / Listed / Tested by various international testing authorities.



## UL 555/555S - Classified Motorized Fire Smoke Damper

## B-30 Series

Type : Motorized Fire Smoke Damper With Melting Fuse



Model : MSFD-GB-F-30C2-A/R

Fire Rating : 30 Series-3 hour.

Leakage Rating : Class-II

Blade Type : 3V Single Skin; A : Parallel Operation

Construction : Galvanized Steel (GI)

UL Classified (see mark on product)  
 UL Classified to American/Intl safety standards  
 UL Standard 555 (Listing # R21925)

Standard Sizes Any Combination of W x H			
Width (W)	Height (H)	Depth (D)	Module
4"	4"	16"	Single
6"	6"	16"	Single
8"	8"	16"	Single
10"	10"	16"	Single
12"	12"	16"	Single
16"	16"	16"	Single
20"	20"	16"	Single
24"	24"	16"	Single
30"	30"	16"	Single
36"	36"	16"	Single

Minimum Sleeve thickness for Breakeaway joints as per NFPA 90A Table 3-4.6.3			
Air Duct Diameter or Maximum Width		Minimum sleeve thickness	
Inch	mm	Inch	gauge
12 or Less	305	0.018	26
13-30	330-762	0.024	24
31-54	787-1372	0.03	22
55-84	1397-2134	0.036	20
85 or more	2159	0.047	18

Size Limitation		
Module	Size : Width X Height	Mounting Position
Single	Min X Min. 4" x 4"	H
Single	Max X Max. 36" x 36"	H

Selected Products of the company have been Classified / Listed / Tested by various international testing authorities.